Distributed generation voltage synchronization when the state changes from islanding to grid connected

Vahid Entezam [1], Mohsen Saniei [2]

1- MSc Student in Electrical Engineering, Dezful Branch, Islamic Azad University, Dezful, Iran,
2-Shahid Chamran University of Ahvaz, Ahvaz, Iran. m.saniei@scu.ac.ir

Abstract:

In this paper a control scheme for grid-connected operation mode and the island state of distributed generation is presented. In normal conditions, every inverter DG system in micro-grids to supply a Preset power, normally operate in a constant current control mode. When micro-grids removed from the network, DG inverter of each system must recognize the island and change position to voltage control mode. In this situation micro-grids supply the fixed voltage to local load. In this paper, a synchronization algorithm is provided for reconnection to the network. The results of the simulation DG, network controllers, and the islanding is provided in MATLAB Simulink.

Keywords: Distributed Generation(DG), Reconnection, Islanding, Sychronization

[DOR: 20.1001.1.23222468.1392.2.1.6.5]
[Downloaded from jeps.dezful.iau.ir on 2026-11-12]
Journal of Novel Researches on Electrical Power - Vol. 2-No. 1- spring 2013